

PUBLIC HEALTH ENGINEERING DEPARTMENT

DISTRICT WATER TESTING LABORATORY, YAMUNA NAGAR

Website :- <https://phedharyana.gov.in/>

Memo No:-

250

Date:-

04/03/2024

Subject : Bacteriological Examination Report of Water Sample

Sample ID:	YNR/04619/2/2024	Sample Details	Date & Time
Sample Classification:	Private	Collected By	SARASWATI VIDY...,8168245226
Sender:	SARASWATI VIDYA MANDIR SR SEC SCHOOL JAGADHRI28596	Collection Date	27/02/2024 at 08:25
Location :-	, OPP SP HOSPITAL BURIA CHOWK JAGADHRI	Received at lab	28/02/2024 at 10:51
Latitude :-	77.313945	Tested at Lab	04/03/2024
Longitude :-	30.159878		

Test Result (As Per BIS 10500 :2012)

S.No.	Tested Parameter	Result	Requirement (Acceptable Limit)	Protocol Used
1	Total Coliform per 100 ml	0	Shall not be detectable in any 100 ml sample	IS 15185:2016/ APHA 9221C; 2017

Remarks :-

- * The Results Given above are related to the sample as received and tested in YAMUNA NAGAR lab.
- * The test report can't be regenerated in whole or part there of without written permission of Competent Authority.
- * The test report can't be used for any publicity or any legal purpose.
- * Reliability of water sample sample lies with sender/collector of water sample.
- * To check the sample report online Scan the QR Code below.

Water Sample has been found "**CONFORMING**" to Limits set in BIS10500:2012 for the tested parameters. Based on the tested parameters,the water sample is found "**POTABLE**"



Neeraj Mehta
Neeraj Mehta,CHEMIST
PUBLIC HEALTH ENGINEERING DEPARTMENT
DISTRICT WATER TESTING LABORATORY YAMUNA NAGAR
email-chemist.yamunanagar@gmail.com

-----End of Report-----.